



中国国家强制性产品认证证书



SITIiAS
Worldwide Access

证书编号: 2020322310001974

认证委托人名称: 图尔克(天津)传感器有限公司
认证委托人地址: 天津经济技术开发区渤海路34号
生产者名称: 汉斯图尔克有限公司
生产者地址: 鲁尔区米尔海姆威茨雷本大街7号
生产企业名称: 维尔纳尔图尔克有限公司
生产企业地址: Kirchlocher Weg 7, 58553 Halver, Germany

产品名称: 网关
系列、规格、型号: GDP-IS/FWa
标 准: GB 3836.1-2010、GB 3836.4-2010

上述产品符合强制性产品认证实施规则 **CNCA-C23-01:2019** 的要求, 特发此证。

发证日期: 2020年9月25日 有效期至: 2025年9月24日

首次发证日期: 2020年9月25日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322310001974

APPLICANT: Turck (Tianjin) Sensor Co., Ltd.
ADDRESS: No.34 Bohai Road, TEDA, Tianjin, P.R.China
MANUFACTURER: Hans Turck GmbH & Co. KG
ADDRESS: Witzlebenstr. 7, 45472 Mülheim an der Ruhr
FACTORY: Werner Turck GmbH & Co.,KG
ADDRESS: Kirchlocher Weg 7, 58553 Halver, Germany
PRODUCTNAME: Excom module gateway
SERIES,SPECIFICATION,MODEL: GDP-IS/FWa
STANDARDS: GB 3836.1-2010、GB 3836.4-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:September 25, 2020

Valid until: September 24, 2025

Date of original certification:September 25, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0001262



中国国家强制性产品认证证书



证书编号: 2020322310001974

附 件

产品名称: 网关

型号规格: GDP-IS/FW *a*

a 代表版本号, 可以为 2.2 或 2.3

防爆标志: Ex ib IIC T4 Gb

电气参数: GDP-IS..型网关必须安装在 excom 远程 I/O 系统 MT 系列母板上。

交流电源电压最大值为 20Va.c.(幅值), 频率介于 300kHz~314kHz 之间, 耗散功率为 1.0W。

RS 485 现场总线“D”型插座 (system module rack, pins 3,5,6,8) 的本安参数为:

最高输出电压 U _o (V)	最高输出电压 U _o (V)	最大输出功率 P _o (mW)	最高输入电压 U _i (V)
3.6	125	112.5	4.2

外部 RS 485 现场总线系统:

最高输入电压 U _i (V)	最大输入电流 I _i (A)
4.2	4.8

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322310001974

附 件

电缆应选用满足标准 GB3836.18-2010 规定且符合下列要求的 A 型或 B 型电缆:

$L'/R' \leq 15 \mu\text{H}/\Omega$ (回路电阻) $C' \leq 250 \text{nF}/\text{km}$ 标准直径 $\geq 0.2 \text{mm}$

批 准:



上海仪器仪表自控系统检验测试所有限公司